

**Stage 2 Disinfectants and Disinfection Byproducts Rule Reporting Spreadsheet**

**Water System:** DC Water  
**PWSID:** DC0000002  
**Report Period:** 2st Quarter 2013

- Steps: 1. Use data from three previous quarters  
 2. Enter sample date and results for current quarter of monitoring in the blue column.  
 3. Summarize results for the quarter. The number of samples should include the number of any repeat samples.

**Total Trihalomethanes (TTHM)**  
 Reported as mg/L or ppm

Number of TTHM samples taken per quarter: 12  
 Operational Evaluation Levels exceeded (Yes/No): No  
 TTHM MCL violations: No

Scheduled Sample Week		Three Most Recent Quarters of Sampling Results*			Current Quarter	Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
Actual Sample Date:		August 2012	November 2012	February 2013	May 2013		
Location ID	Location Name						
1H-9	1700 EAST CAPITOL ST NE	0.068	0.030	0.021	0.021	0.023	0.035
1H-10	900 F ST NE	0.071	0.031	0.018	0.018	0.021	0.035
2H-1 BKJV	1731 BUNKER HILL RD NE	0.063	0.025	0.018	0.018	0.020	0.031
2H-8	1801 HAMLIN ST NE	0.064	0.024	0.020	0.020	0.021	0.032
3H-4 BKJV	1640 KALMIA RD NW	0.062	0.026	0.016	0.016	0.019	0.030
3H-13	120 KENNEDY ST NW	0.063	0.025	0.014	0.014	0.017	0.029
4H-3	5701 BROAD BRANCH RD NW	0.062	0.024	0.015	0.015	0.017	0.029
A1H-3 BKJV	420 56TH ST NE	0.062	0.035	0.020	0.020	0.024	0.034
A1H-8	3125 MARTIN LUTHER KING AVE SE	0.064	0.034	0.020	0.020	0.024	0.035
L-1 BKJV	4800 MEADE ST NE	0.064	0.030	0.020	0.020	0.023	0.034
L-4	550 WATER ST SW	0.058	0.029	0.019	0.019	0.022	0.031
L-12	5000 OVERLOOK AVE SW	0.070	0.031	0.022	0.022	0.024	0.036
						If TTHM OEL is > 0.080, perform Operational Evaluation.	If TTHM LRAA is > 0.080, MCL violation occurred.

**Five Haloacetic Acids (HAA5)**  
 Reported as mg/L or ppm

Number of HAA5 samples taken per quarter: 12  
 Operational Evaluation Levels exceeded (Yes/No): No  
 HAA5 MCL violations: No

Scheduled Sample Week		Three Most Recent Quarters of Sampling Results*			Current Quarter	Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
Actual Sample Date:		August 2012	November 2012	February 2013	May 2013		
Location ID	Location Name						
1H-9	1700 EAST CAPITOL ST NE	0.039	0.025	0.023	0.023	0.023	0.027
1H-10	900 F ST NE	0.041	0.028	0.020	0.020	0.022	0.027
2H-1 BKJV	1731 BUNKER HILL RD NE	0.038	0.022	0.022	0.022	0.022	0.026
2H-8	1801 HAMLIN ST NE	0.038	0.023	0.023	0.023	0.023	0.027
3H-4 BKJV	1640 KALMIA RD NW	0.011	0.010	0.011	0.011	0.011	0.011
3H-13	120 KENNEDY ST NW	0.033	0.021	0.010	0.010	0.013	0.019
4H-3	5701 BROAD BRANCH RD NW	0.043	0.018	0.011	0.011	0.013	0.021
A1H-3 BKJV	420 56TH ST NE	0.039	0.022	0.024	0.024	0.023	0.027
A1H-8	3125 MARTIN LUTHER KING AVE SE	0.028	0.025	0.021	0.021	0.022	0.024
L-1 BKJV	4800 MEADE ST NE	0.006	0.007	0.019	0.019	0.016	0.013
L-4	550 WATER ST SW	0.039	0.022	0.021	0.022	0.022	0.026
L-12	5000 OVERLOOK AVE SW	0.046	0.024	0.022	0.021	0.022	0.028
						If HAA5 OEL is > 0.060, perform Operational Evaluation.	If HAA5 LRAA is > 0.060, MCL violation occurred.

\* Results of Stage 2 Disinfectants & Disinfection Byproduct Rule Monitoring only. Stage 1 results should not be used for LRAA or OEL.